

The manufacturer is granted the following type test approval mark in virtue of a test report:

Category test approval mark:

[safety valve](#)

Technical inspection and surveillance organisation and test report:

TÜV Rheinland Industrie Service GmbH dated 2022-01-12

Manufacturer/Circulator:

[Thies Armatur GmbH & Co. KG](#)
[Gutenbergstraße 2](#)
[31157 Sarstedt](#)
[GERMANY](#)

Type test approval mark:

[TÜV . SV . 22 - 662 . d₀ . D/G/H . α_w . p](#)

Design:

direct-acting safety valve, spring-loaded

Type:

[341](#)

The adjudication is made pursuant to:

- VdTÜV-Merkblatt Sicherheitsventil 100, edition 2017-04, in conjunction with VdTÜV-Merkblatt Allgemeines 002, Ausgabe 2019-02
- Directive 2014/68/EU of 15.05.2014 in the version of 23.06.2015 (pressure equipment directive)
- AD 2000-Merkblatt A 2, edition 2020-01
- AD 2000-Merkblatt A 4, edition 2015-11
- DIN EN 12828:2014-07, appendix E
- DIN EN ISO 4126-1:2016-12 + A2:2019-06
- DIN EN ISO 4126-7:2016-12
- TRD 721:1982-05

Valid until:

[2027-01-31](#)

The adjudication is revocable. The previous certificate is replaced herewith.

Note: The manufacturer or importer is obliged to the competent Authorized Inspector to conduct a random check on the accessories concerning identity to the type once a year. The accessories have to be taken from the current production.

TÜV-Verband e. V.
Friedrichstraße 136
10117 Berlin

phone: +49 30 760095-400
e-mail: bauteile@tuev-verband.de

division industry and plant engineering

www.tuev-verband.de/en